



PRIMARY HEALTH CARE CENTRE SHETTIHALLI GATE, TUMAKURU.

Phone: 0816-2955837

E-mail: phcshettyhalligate@gmail.com

No.: 38/2024-25

Date: 10/07/2024

WATER SAMPLE ANALYSIS REPORT – 2024

Sl. No.	Examined Date	A place where water is collected	E Coli A Absent P Present	MPN Count	Result
01	08/07/2024	Sree Gurukul Primary and High School, 2 nd Cross, 2 nd Block, Siddarameshwara Extension, Tumkur Taluk, Tumkur District.	0	0/100	FIT TO DRINK

Medical Officer
Primary Health Care Centre
Shettihalli Gate, Tumakuru

Note: MPN Count: Most Probable Number of Bacteria per 100ml of water.

Fecal coliform count: Thermotolerant coliforms present in 100ml of water.
Bleaching powder required = $(9.4 \times d \times h) / 4$ gms where d=diameter of the well (in mtrs): and h=height of the waer column in mts.

Note:

1. Take appropriate action according to the results of the laboratory and report the same to the district surveillance officers without fail.
2. In the above water samples, non-potable water samples are subjected to chlorination and after 10 days the water sample is again analysed.

Interpretation of Water Report

MPN Count	Fecal Coliform count	Result	Remarks
0	0	Excellent	No action required
1-3	0	Satisfactory	No action required
4-10	0	Suspicious	Chlorination required
>10	1 or more	Unsatisfactory	Chlorination required



PRIMARY HEALTH CARE CENTRE SHETTIIHALLI GATE, TUMAKURU.

Phone: 0816-2955837

E-mail: phcshettyhalligate@gmail.com

No.: 36/2024-25

Date: 10/07/2024

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Sheksabjan** from Medical Officer, Primary Health Centre, Tumkur inspected the **Sree Gurukul Primary and High School, 2nd Cross, 2nd Block, Siddarameshwara Extension, Batawadi, Tumkur Taluk** on 06/07/2024 and on the basis of water test report bearing no. **36/2024-25** dated 10/07/2024 of District Public Health Laboratory Tumkur District Surveillance Unit, Tumkur-572103 certified that the **Sree Gurukul Primary and High School, 2nd Cross, 2nd Block, Siddarameshwara Extension, Tumkur Taluk, Tumkur District** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central / State / U.T. Government.

This certificate is valid till 10/07/2025

Medical Officer
Primary Health Care Centre
Shettihalli Gate, Tumakuru

Signature

To,
The Sree Gurukul Primary and High School
2nd Cross, 2nd Block,
Siddarameshwara Extension,
Tumkur District, Karnataka.



**PRIMARY HEALTH CARE CENTRE
SHETTIHALLI GATE, TUMAKURU.**

Phone: 0816-2955837

E-mail: phcshettyhalligate@gmail.com

No.: 37/2024-25

Date: 10/07/2024

ನೀರಿನ ಮಾದರಿಗಳ ವಿಶ್ಲೇಷಣಾ ವರದಿ 2024

ಕ್ರಮ ಸಂಖ್ಯೆ	ಪರೀಕ್ಷಿಸಿದ ದಿನಾಂಕ	ನೀರು ಸಂಗ್ರಹಿಸಿದ ಸ್ಥಳ	ಈ. ಕೋಲ್ಯೆ	ನಿ	ಫಲಿತಾಂಶ
01	08/07/2024	ಶ್ರೀ ಗುರುಕುಲ್ ಪ್ರೈಮರಿ ಮತ್ತು ಪ್ರೌಢಶಾಲೆ, 2ನೇ ಕ್ರಾಸ್, 2ನೇ ಬ್ಲಾಕ್, ಸಿದ್ದರಾಮೇಶ್ವರ ಬಡಾವಣೆ, ತುಮಕೂರು-03.	0	0/100	ಯೋಗ್ಯವಿದೆ.

Translated by

S.V. Sudhamani
S.V. SUDHAMANI, B.Com., LL.B.
ADVOCATE & NOTARY
GOVT. OF INDIA
Maruthi Nilaya, Madanana Palaya
Siragata, Tumakuru 572106
KARNATAKA

[Signature]
Medical Officer
Primary Health Care Centre
Shettihalli Gate, Tumakuru

Note: MPN Count: Most probable number of bacteria per 100 ml of water.

Fiscal coliform count : thermotolerant coliforms present in 100ml of water.
Bleaching powder required = $(9.4 \times d^2 \times h) / 4\text{gms}$ where d = diameter of the well (in mtrs.) and H=height of the water column in mtrs.

ಸೂಚನೆ:

- ಪ್ರಯೋಗಶಾಲೆಯ ಫಲಿತಾಂಶಕ್ಕೆ ಅನುಗುಣವಾಗಿ ಸಲೂಕ್ಷಕಮಗಳನ್ನು ತೆಗೆದುಕೊಂಡು ಅದರ ವರದಿಯನ್ನು ಜಿಲ್ಲಾ ಸರ್ವೇಲಿಸ್ಟ್ ಅಧಿಕಾರಿಗಳಿಗೆ ತಪ್ಪದೇ ಕಳುಹಿಸುವುದು.
- ಮೇಲ್ಕಂಡ ನೀರಿನ ಮಾದರಿಗಳಲ್ಲಿ ಕುಡಿಯಲು ಯೋಗ್ಯವಲ್ಲದ ನೀರಿನ ಮಾದರಿಗಳನ್ನು ಕ್ಲೋರಿನೇಷನ್‌ಗೆ ಒಳಪಡಿಸಿ 10 ದಿನಗಳ ನಂತರ ನೀರಿನ ಮಾದರಿಯನ್ನು ಮತ್ತೊಮ್ಮೆ ವಿಶ್ಲೇಷಣೆಗೆ ಒಳಪಡಿಸುವುದು.

Interpretation of Water Report

MPN Count	Fecal Coliform count	Result	Remarks
0	0	Excellent	No action required
1-3	0	Satisfactory	No action required
4-10	0	Suspicious	Chlorination Required
>10	1 or more	Excellent	No action required